



Enbridge
Suite 300 – 890 Winter Street
Waltham, Massachusetts 02451
USA

April 6, 2021

Mr. Thomas Cushing
Bureau of Air & Waste – Air Permit Chief
MassDEP Southeast Regional Office
20 Riverside Drive
Lakeville, MA 02347

RE: *Notification of Unplanned Natural Gas Release
Algonquin Gas Transmission, LLC
Weymouth Compressor Station (Transmittal No. X266786)*

Dear Mr. Cushing:

Algonquin Gas Transmission, LLC (Algonquin) was issued Air Quality Plan Approval - Transmittal No. X266786 (the Plan Approval) by the Massachusetts Department of Environmental Protection (MassDEP) on August 26, 2019. The Plan Approval authorizes the construction and operation of the Weymouth Compressor Station, 54 Bridge Street, North Weymouth, Massachusetts.

This is to inform you that an unplanned gas release occurred on April 6th, 2021 at approximately 9:37 am. The gas was released in a controlled manner through the case vent stack, which is designed to safely vent natural gas. In accordance with Section 3.B., Table 11, Condition 3 of the Plan Approval for the Weymouth Compressor Station, Algonquin is required to notify MassDEP within 2 hours of any unplanned gas releases at the Weymouth Compressor Station that exceed 10,000 standard cubic feet (scf) of natural gas.

Algonquin will follow up with more information within 3 business days, including an estimate of the actual volume of gas released.

A handwritten signature in black ink that reads 'Roy Taylor'.

Roy Taylor – Director Field Operations, Northeast Region

Cc: Frank Pike, Enbridge
Town of Weymouth
City of Quincy
Town of Braintree
Town of Hingham